



STANDARDSMARK LICENCE

SAI Global hereby grants:

CRM Melbourne Pty Ltd

ABN 76 611 676 094

Unit 5/15-23 Sinnott Street, Burwood, VIC 3125, Australia

StandardsMark Licence

Manufactured to:

AS 2047-2014 - Windows and external glazed doors in buildings - This certification excludes installation

"the StandardsMark Licensee" the right to use the STANDARDSMARK as shown below only in respect of the goods described and detailed in the Schedule which are produced by the Licensee or on behalf of the Licensee* and which comply with the appropriate Standard referred to above as from time to time amended. The Licence is granted subject to the rules governing the use of the STANDARDSMARK and the Terms and Conditions for certification and licence. The Licensee covenants to comply with all the Rules and Terms and Conditions.

Licence No: SMK40655

Issued : 28 October 2016

Expires : 27 October 2021

Originally Certified : 28 October 2016

Current Certification : 28 October 2016

Paul Simpson
Global Policy Risk and Certification Manager



Australian
Standard

* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to www.saiglobal.com, for the list of product models.

SCHEDULE TO STANDARDSMARK LICENCE

SAI Global hereby grants:

CRM Melbourne Pty Ltd

Unit 5/15-23 Sinnott Street, Burwood, VIC 3125, Australia

StandardsMark Licence

Manufactured to:

AS 2047-2014 - Windows and external glazed doors in buildings - This certification excludes installation

Model identification of the goods on which the STANDARDSMARK may be used:

Window Type	Model	Max Size (mm)	Servicability Limit Design Wind Pressure (Pa) (span/100)	Servicability Limit Design Wind Pressure (Pa) (span/250)	Ultimate Limit Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Infiltration Rating (L/s m2)	Date Endorsed
Aluminum casement window with fixed sash	CRM-T001	1200 X800	NA	1600	4000	1500	Low, +75Pa:0.04, -75Pa:0.06	17 Oct 2016

End of Record

Licence No: SMK40655

Issued Date: 28 October 2016

This schedule supersedes all previously issued schedules



* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to www.saiglobal.com, for the list of product models.